



# BARROW COUNTY *Georgia*

## MEMORANDUM – ADDENDUM # 2

**To:** Interested Vendors  
**From:** Cindy Clack & Misty Landers  
**Date:** 7/18/2016  
**Re:** RFB2016-17 Old Hog Mountain Road Resurfacing -- Addendum # 2

---

### QUESTIONS

The Special Provision on page 61 states the work of building shoulders should be included in the price of the 2' paved widening. Since there is not a pay item for grading complete,

- 1) Is the Contractor responsible for rebuilding the shoulders after the 2' widening and paving is complete? *See Addendum # 1.*

Several areas along the roadway do not have adequate shoulders to allow for an additional 2' paved widening.

- 1) Will the County be able to build the shoulders so that the 2' widening can be installed? *See Addendum # 1.*
- 2) Will the Contractor be allowed to skip those areas? *The contractor will not be able to skip.*
- 3) Will the County be responsible for removing and replacing any mailboxes and/or utilities that may conflict with the 2' paved widening and machinery? *See General Conditions # 7 in the proposal documents.*

If the County is responsible for the shoulder building:

- 1) Is the County or Contractor responsible for the installation and removal of low/soft shoulder signage? *See Addendum # 1.*

As part of the 2' paved widening,

- 1) Will the County require a milling machine to cut out the 2' widening and remove all the excavated material from the project entirely; or
- 2) May a motor grader be used to cut out the 2' widening and the excavated material be windrowed/stored along the site until the shoulders are to be constructed? *A milling machine will be required to cut out the 2' widening.*