



BARROW COUNTY *Georgia*

MEMORANDUM – ADDENDUM # 1

To: Interested Vendors

From: Cindy Clack

Date: 11/14/2016

Re: RFB2017-1 -- 5.0 MG Ground Storage Tank Mixing System Upgrades

The following questions have been submitted for RFB2017-1:

Questions:

- In looking at your project, can you provide if you are open to all solutions?

Response:

Barrow County is open to solutions local to the 5.0 MG Tank.

- It appears there is most likely a chlorination or other like process creating the THM situation, which is the norm, Can you confirm this and confirm the input is consistent?

Response:

Yes, we are disinfecting with chlorine.

- Can we clarify if we are looking for a mixer solution or one for THM removal which appears more likely to be the issue we are trying to resolve?

Response:

Yes, we are looking for options for both.