


# Barrow County Board of Commissioners

30 North Broad Street Winder Georgia 30680 Phone: (770) 867-1977 Fax: (770) 868-8666

Cindy F. Clack  
Purchasing Agent



## MEMORANDUM – ADDENDUM NO. 3

To: Interested Vendors

From: Cindy Clack

Date: 5/1/2015

Re: RFP2015-9 – Courthouse and Jail CCTV System Enhancements – Addendum #3

THIS ADDENDUM is hereby made a part of the Contract Documents dated May 1, 2015 on the subject work as though originally included therein. The following amendments, additions and/or corrections shall govern this work.

This Addendum is in three parts as follows:

- Part I - Pertaining to Questions from Bidders
- Part II - Pertaining to Contract Documents
- Part III - Pertaining to Drawings

### PART I – PERTAINING TO QUESTIONS FROM BIDDERS

#### A3-1. Questions of Bidders

- a. What version of Wonderware is installed in the system, how many tags are associated with it and are the HMI and PLC passwords available. The system passwords are available. Wonderware V10 is installed. The original integrator does not recall the exact number of tags purchased for each license but believes it to be 60,000 (unlimited). The licensing information from the software appears to uphold that belief.
- b. Can we utilize Ethernet over Coax for ALL coaxial cameras no matter what the distance, including less than 300'? – NO, if Alternate 2 is accepted, use specified CAT 6 cabling at all cameras 300' or less from the security equipment room.
- c. Is the Pre-Construction Video required? – YES
- d. Is there any particular color the owner is requesting for Cat 6 cable? – YES, Yellow.
- e. Are the under counter keyboard trays for CCTV existing or are they to be provided? They are to be provided.
- f. Do we provide new equipment, CPU's Monitors and printer for the Archive and Viewing stations? See response in Part II.
- g. Integration of all CCTV control functions is on Customer's existing computers and Touch Screens, Correct? Yes and No – the PLCs are an essential part of the integration. The Human Machine Interface (HMI) software, Wonderware, and data logging software is resident on the owner's equipment.

- h. Will the County accept a certified check made out to them in lieu of a bid bond? O.C.G.A. Sec. 36-91-51 (a) does indeed allow the County to accept a certified check in lieu of a bid bond.

**PART II – PERTAINING TO CONTRACT DOCUMENTS**

A3-2. Document 282300 – INTEGRATED VIDEO SURVEILLANCE SYSTEMS

- a. Re: Paragraph 1.2.D. and 2.9.B.10.
  - i. The requirement for video storage in this paragraph conflict with the requirements found in 28 2300 2.9.B.10. Which is correct? The requirements for video storage are correctly cited in 28 2300 1.2.D - 30 days. The requirements shown in 28 2300 2.9.B.10 are incorrect. The requirement in both passages should state 30 days. Please also see other modifications to this requirement in A3.2.c. below.
- b. Re: Paragraph 2.13
  - i. The requirement of this paragraph for new video archiving and viewing equipment conflicts with instructions on sheet X7.01 of the project drawings. The instruction of Drawing X7.01 is correct. USE EXISTING EQUIPMENT – however, at Room A0028 the existing video archiving station utilizes a DELL OPTIPLEX 330 CPU. A new DELL OPTIPLEX 3010 CPU has been provided and is immediately adjacent to the 330 but has not been initiated. Use the new DELL CPU for the archiving station.
- c. Re: Paragraph 1.2.D. and 2.9.B.10.
  - i. The requirement of these paragraphs is modified as follows. All camera video will be retained for 30 day in accordance with the specification requirement except for six cameras in holding areas. The video from these six cameras will be retained for 5 years. Provide a separate storage appliance for these cameras.

**PART III – PERTAINING TO DRAWINGS**

None

**ATTACHMENTS TO THIS ADDENDUM:**

None

**END OF THIS ADDENDUM**