



## MEMORANDUM – ADDENDUM NO. 4

**To:** Interested Vendors  
**From:** Cindy Clack  
**Date:** 11/24/2025  
**Re:** RFB2026-08 Rebid Northwest Elevated Water Storage Tank -- Addendum No 4 (1 Page)

---

---

Please see below for questions/answers that have been received to date.

**Clarification:** Addendum No. 4 is the final addendum that will be issued for this project, no questions submitted after addendum is posted will be answered.

### **Questions/Answers:**

**Q1.** *Can you please confirm that prevailing wages do not apply to this project?*

A1. Confirmed.

**Q2.** *In reference to Addendum Drawings, Sheet 03 of the Plans (or any of the other site overview pages), we don't see where a Jack & Bore are expected to be placed, however, we assume one is needed due to the W19 detail shown on Sheet 07 of the Plans (Addendum 1). Could you please clarify where detail W19 is expected?*

A2. W19 is not expected to be used, there is no jack and bore of this project.

**Q3.** *In reference to Addendum 1 Sheet 09 (screenshot below) & Sheet 10:*

*Rock Outlet on Sheet 10 of Plans (Sd4-C detail), looks like the Rock Outlet Berm is either replacing the existing headwall or is running alongside/near the headwall but it's not shown or referenced clearly on Sheet 09 of the Site View... therefore, it's not clear what is expected. (You'll see on Sheet 10 (RB1 Detail) is shown & there is a reference for location of RB1 detail on Sheet 09... we are looking for something like this for Sd4-C, so we can quantify material and location. I do see the note of ".81 AC Drainage Area for SD4-C" on sheet 09, however, that seems like a general area note, not a specific location.) Could you please help clarify?*

A3. There are no existing headwalls; the headwall at station 0+28 is new. The rip rap extending from the headwall to the bottom of the pond is included in the bid item for rip rap. This is the inlet side of the Sd4-C. The Rock Outlet for the temporary sediment trap is located on the southwest side of the Sd-4 adjacent to the spreader berms. Rip rap for the Rock Outlet is included in bid item 4 for the Rock Outlet Temp. Sediment Trap (Sd4-C). The rip rap for the spillway for the Rock Outlet for the Sd4-C is not shown with a rip rap symbol; it is all part of the Sd-4C Temporary Sediment Trap detail shown on sheet 10.

**Q4.** *I highlighted the berm for the rock outlet that I'd like clarification on it's location and length.*

A4. See answer to question 3.